

---

## Dangerous Occurrence Uncontrolled Ammonia Release

---

**When:** 20<sup>th</sup> January 2016

**Where:** Customer Site Location

**No:** 16/035

**Potential Injury Description:**

Ammonia vapor inhalation and/or burns.

**Incident Details:**

Whilst starting to purge ammonia vapour from a compressor package into water, two J & E Hall engineers allowed an un-controlled ammonia release as the pipe fell out of the water IBC container briefly and allowed ammonia vapour to be released into a pedestrian area. Two members of the site's staff were stood across the road (approximately 15 / 20 metres from the purging vessel). After the event they asked one of the engineers what was being purged and the engineer told them that it was ammonia. One guy then walked across site and reported that he had been covered in ammonia vapour.

J & E Hall engineers have stated that the incident happened as they started work, one engineer was at the purge valve on the compressor and the other engineer by the water IBC container, (eight to ten metres apart) as the engineer opened the purge valve the un-fixed purge hose was pushed out of the water causing the ammonia vapour release, at this point the engineer shouted to the other engineer and the ammonia purge valve was shut.

**A second incident had also been raised by the customer:**

The customer site contact had contacted the service centre manager to state that the engineers had left the system purging ammonia into the water overnight, so it would be clear in the morning for them to start work on the compressor. The service centre manager therefore rang the engineers and got them to turn around and go back to site to isolate the purging.

**Root Causes:**

- The hose was not affixed to the IBC container
- The J & E Hall risk assessment and method statement had not been signed as read and understood by the engineers
- The working area was not cordoned off and no safety warning signage was put on display, as per the issued J & E Hall risk assessment and method statement documents issued to the engineers and site
- As the engineers had been purging ammonia for at least six hours the previous day, the 1000 litre IBC container of water could have been saturated with ammonia, thus when the ammonia purge valve was opened the next day, the water would not have absorbed the ammonia, thus forcing the hose out of the water
- If the engineer opened the purge valve too aggressively, then this and the above saturated water could have driven the hose out of the water, blowing ammonia vapour across the un-cordoned pedestrian area
- Uncontrolled and unsupervised purging of ammonia should it have been left as intended by the engineers overnight

